

CERTIFICATE OF TYPE TESTS

Laboratory Ref. No: 1624.2090742.0730

Certificate No. 17242

APPARATUS: 1250 A / 400 V / 1000 V (I_n / U_e / U_i), 50 Hz Busbar trunking system, three-phase main busbar system + N and PE (Housing)

DESIGNATION: GS 1250A

MANUFACTURER: GERSAN Elektrik Tic. ve San. A. S.
Tuzla Mermerciler Org. San. Bölgesi
yanyol cad. no. 6
P.K:57 TUZLA-ISTANBUL
TURKEY

TESTED BY: Institut „Prüffeld für elektrische Hochleistungstechnik“ GmbH
Landsberger Allee 378A
12681 Berlin, GERMANY

MPA Dresden GmbH
Fuchsmühlenweg 6 F
09599 Freiberg, GERMANY

RST Rail System Testing GmbH
Am Rathenaupark
16761 Hennigsdorf, GERMANY

DATE(S) OF TESTS: 16 September to 14 October 2009

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with:

IEC 60439-2: 2005-10, Sub-clauses 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7,
8.2.9, 8.2.10, 8.2.12, 8.2.13, 8.2.14 and 8.2.15

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by test see Pages 1 and 2.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 56 pages, 7 diagrams, 3 oscillograms, 11 photographs, 6 drawings and no other sheets.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from Intertek, Hilton House, Corporation Street, Rugby, Warwickshire, CV21 2DN, United Kingdom.



010

J. Haring
P. Gills
10TH March 2010

ASTA Observer
J. Haring
Certification
Manager

Date

ASTA

CERTIFICATE OF TYPE TESTS

Laboratory Ref. No: **1624.2090743.0731** Certificate No. **17243**

APPARATUS: 1600 A / 400 V / 1000 V (I_n / U_e / U_i), 50 Hz Busbar trunking system, three-phase main busbar system + N and PE (Housing)

DESIGNATION: GS 1600A

MANUFACTURER: GERSAN Elektrik Tic. ve San. A. S.
Tuzla Mermerciler Org. San. Bölgesi
yanyol cad. no. 6
P.K:57 TUZLA-ISTANBUL
TURKEY

TESTED BY: Institut „Prüffeld für elektrische Hochleistungstechnik“ GmbH
Landsberger Allee 378A
12681 Berlin, GERMANY

MPA Dresden GmbH
Fuchsmühlenweg 6 F
09599 Freiberg, GERMANY

RST Rail System Testing GmbH
Am Rathenaupark
16761 Hennigsdorf, GERMANY

DATE(S) OF TESTS: 21 September to 14 October 2009

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with:

IEC 60439-2: 2005-10, Sub-clauses 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12, 8.2.13, 8.2.14 and 8.2.15

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by test see Pages 1 and 2.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 59 pages, 7 diagrams, 5 oscillograms, 11 photographs, 6 drawings and no other sheets.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from Intertek, Hilton House, Corporation Street, Rugby, Warwickshire, CV21 2DN, United Kingdom.



010

J. Haring
P. J. Haring
10th March 2010

ASTA Observer
J. Haring
Certification
Manager

Date

CERTIFICATE OF TYPE TESTS

Laboratory Ref. No: **1624.2090744.0732** Certificate No. **17244**

APPARATUS: 2000 A / 400 V / 1000 V (I_n / U_e / U_i), 50 Hz Busbar trunking system, three-phase main busbar system + N and PE (Housing)

DESIGNATION: GS 2000A

MANUFACTURER: GERSAN Elektrik Tic. ve San. A. S.
Tuzla Mermerciler Org. San. Bölgesi
yanyol cad. no. 6
P.K:57 TUZLA-ISTANBUL
TURKEY

TESTED BY: Institut „Prüffeld für elektrische Hochleistungstechnik“ GmbH
Landsberger Allee 378A
12681 Berlin, GERMANY

MPA Dresden GmbH
Fuchsmühlenweg 6 F
09599 Freiberg, GERMANY

RST Rail System Testing GmbH
Am Rathenaupark
16761 Hennigsdorf, GERMANY

DATE(S) OF TESTS: 24 September to 16 October 2009

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with:

IEC 60439-2: 2005-10, Sub-clauses 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12, 8.2.13, 8.2.14 and 8.2.15

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by test see Pages 1 and 2.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 59 pages, 7 diagrams, 5 oscillograms, 11 photographs, 6 drawings and no other sheets.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from Intertek, Hilton House, Corporation Street, Rugby, Warwickshire, CV21 2DN, United Kingdom.



010

J. Haring
P. Haring
10TH MARCH 2010

ASTA Observer
J. Haring
Certification
Manager

Date

ASTA

CERTIFICATE OF TYPE TESTS

Laboratory Ref. No: 1624.2080607.713

Certificate No. 16936

APPARATUS: 2500 A / 400 V / 690 V (I_n / U_e / U_i), 50 Hz Busbar trunking system, three-phase main busbar system + N and PE (Housing)

DESIGNATION: GS 2500A

MANUFACTURER: GERSAN Elektrik Tic. ve San. A. S.
Tuzla Mermerciler Org. San. Bölgesi
yanyol cad. no. 6
P.K:57 TUZLA-ISTANBUL
TURKEY

TESTED BY: Institut „Prüffeld für elektrische Hochleistungstechnik“ GmbH
Landsberger Allee 378A
12681 Berlin, GERMANY

MPA Dresden GmbH
Certificated testing laboratory for fire-fighting mediums and equipment
Fuchsmühlenweg 6 F
09599 Freiberg, GERMANY

DATE(S) OF TESTS: 02 September to 06 October 2008

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with:

IEC 60439-2: 2005-10, Sub-clauses 8.2.1, 8.2.2, 8.2.3, 8.2.4.2, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.2.10, 8.2.12, 8.2.13, 8.2.14 and 8.2.15

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by test see Pages 1 and 2.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 58 pages, 7 diagrams, 5 oscillograms, 11 photographs, 6 drawings and no other sheets.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from ASTA BEAB Certification Services, Hilton House, Corporation Street, Rugby, Warwickshire, CV21 2DN, United Kingdom.



010

J. Haring
R. Hayward
6th August 2009

ASTA Observer
J. Haring

Certification
Manager

Date

CERTIFICATE OF TYPE TESTS

Laboratory Ref. No: 1624.2080608.714

Certificate No. 16937

APPARATUS: 3200 A / 400 V / 690 V (I_n / U_e / U_i), 50 Hz Busbar trunking system, three-phase main busbar system + N and PE (Housing)

DESIGNATION: GS 3200A

MANUFACTURER: GERSAN Elektrik Tic. ve San. A. S.
Tuzla Mermerciler Org. San. Bölgesi
yanyol cad. no. 6
P.K:57 TUZLA-ISTANBUL
TURKEY

TESTED BY: Institut „Prüffeld für elektrische Hochleistungstechnik“ GmbH
Landsberger Allee 378A
12681 Berlin, GERMANY

MPA Dresden GmbH
Certificated testing laboratory for fire-fighting mediums and equipment
Fuchsmühlenweg 6 F
09599 Freiberg, GERMANY

DATE(S) OF TESTS: 02 September to 15 October 2008

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with:

IEC 60439-2: 2005-10, Sub-clauses 8.2.1, 8.2.2, 8.2.3, 8.2.4.2, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.2.10, 8.2.12, 8.2.13, 8.2.14 and 8.2.15

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by test see Pages 1 and 2.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 59 pages, 7 diagrams, 6 oscillograms, 11 photographs, 6 drawings and no other sheets.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from ASTA BEAB Certification Services, Hilton House, Corporation Street, Rugby, Warwickshire, CV21 2DN, United Kingdom.



010

J. Haring
R. Hayward
6th August 2009

ASTA Observer
J. Haring
Certification
Manager

Date

CERTIFICATE OF TYPE TESTS

Laboratory Ref. No: **1624.2090747.0735** Certificate No. **17247**

APPARATUS: 4000 A / 400 V / 1000 V (I_n / U_e / U_i), 50 Hz Busbar trunking system, three-phase main busbar system + N and PE (Housing)

DESIGNATION: GS 4000A

MANUFACTURER: GERSAN Elektrik Tic. ve San. A. S.
Tuzla Mermerciler Org. San. Bölgesi
yanyol cad. no. 6
P.K:57 TUZLA-ISTANBUL
TURKEY

TESTED BY: Institut „Prüffeld für elektrische Hochleistungstechnik“ GmbH
Landsberger Allee 378A
12681 Berlin, GERMANY

MPA Dresden GmbH
Fuchsmühlenweg 6 F
09599 Freiberg, GERMANY

RST Rail System Testing GmbH
Am Rathenaupark
16761 Hennigsdorf, GERMANY

DATE(S) OF TESTS: 25 September to 15 October 2009

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with:

IEC 60439-2: 2005-10, Sub-clauses 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12, 8.2.13, 8.2.14 and 8.2.15

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by test see Pages 1 and 2.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 60 pages, 7 diagrams, 6 oscillograms, 11 photographs, 6 drawings and no other sheets.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from Intertek, Hilton House, Corporation Street, Rugby, Warwickshire, CV21 2DN, United Kingdom.



010

J. Haring
P. Giths
10TH MARCH 2010

ASTA Observer
J. Haring
Certification
Manager

Date

CERTIFICATE OF COMPLETE COMPLIANCE

Laboratory Ref. No: **1624.2080610.716** Certificate No. **16939**

APPARATUS: 5000 A / 400 V / 690 V (I_n / U_e / U_i), 50 Hz Busbar trunking system, three-phase main busbar system + N and PE (Housing)

DESIGNATION: GS 5000A

MANUFACTURER: GERSAN Elektrik Tic. ve San. A. S.
Tuzla Mermerciler Org. San. Bölgesi
yanyol cad. no. 6
P.K:57 TUZLA-ISTANBUL
TURKEY

TESTED BY: Institut „Prüffeld für elektrische Hochleistungstechnik“ GmbH
Landsberger Allee 378A
12681 Berlin, GERMANY

DATE(S) OF TESTS: 02 September to 07 October 2008

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with:

IEC 60439-2: 2005-10, Sub-clauses 8.2.1, 8.2.2, 8.2.3, 8.2.4.2, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.2.10, 8.2.12, 8.2.13, 8.2.14 and 8.2.15

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by test see Pages 1 and 2.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 61 pages, 7 diagrams, 7 oscillograms, 13 photographs, 6 drawings and no other sheets.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from ASTA BEAB Certification Services, Hilton House, Corporation Street, Rugby, Warwickshire, CV21 2DN, United Kingdom.



010

J. Haring
.....
R. Hayward
.....
29th June 2009
.....

ASTA Observer
J. Haring
Certification
Manager

Date